

CALIF ORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7165-0075:200 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653  
Contact: Brian Reynolds (203) 484-1200

DESIGN: Model MS-2 and MS-4 fire alarm control units. Model MS-2 suitable for local, central station and proprietary (protected premises). Model MS-4 suitable for non-coded; local, remote station, auxiliary, proprietary (protected premises) and central station (protected premises) when used with appropriate option modules and additional separate listed equipment; automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

MS-2, -4	Control Unit
411, 411UD, 411UDAC	DACT
4XTMF	Transmission Module
CAC-4	Converter Module

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed compatible initiating and indicating devices. This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996. Refer to manufacturer's Installation Manual for details.

NOTE: For *Fire Alarm Verification* feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

12-14-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**APRIL 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager